

Test Report

Quality Standard	Parameters as desired
Issued to	- Tagore Public School, D Block, Naraina Vihar, New Delhi
Kind attn.	- Mr. Vikas Bhatia
Analysis no.	- 23062205

Nature of Sample	- Water Sample marked Domestic
Sample received on	- 22 nd June 2023
Report Date	- 26 th June 2023
Analysis Dates	- 22 nd June 2023 to 26 th June 2023
Sample receipt	- Picked by Lab
Sample Packing	- Sterilized and Pet Bottles

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	Absent	Absent
	E.Coli	CFU/100ml	Absent	IS1622	Absent	Absent
Physical	pH	Unit Less	7.41	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	260	IS 3025 Part 14	...	—
	Turbidity	NTU	1.3	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	137	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO ₃	mg/l	75.4	IS 3025 Part 23	200	600
	Total Hardness as CaCO ₃	mg/l	104	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	25	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.02	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	—

Remarks: The no. of parameters tested is 14 only. The results indicate that the Quality of water may be considered to be within the desired limits as per IS:10500, in regard to the parameters tested only. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist

Authorized Signatory

Niraj Datta

Manager

TAGORE PUBLIC SCHOOL
D-Block, Naraina Vihar
New Delhi-110028

Reviewed by Sign : *[Signature]*
Designation : Quality Analyst

Issued by Sign : *[Signature]*
Name : Dilip Thakur
Designation : Technical Manager



QUALITY LAB is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charva Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringsshagen No. 7340. OPPDAL, Norway

Exclusive representatives in India for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking